

Ohio River Valley Water Sanitation Commission

Pollution Control Standards

for discharges to the Ohio River


1997 Revision

Notice of Requirements

You are hereby notified that, having considered all the evidence presented at public hearings, the Ohio River Valley Water Sanitation Commission, at its regularly held meeting on January 9, 1997, acting in accordance with and pursuant to the authority contained in Article VI of the Ohio River Valley Water Sanitation Compact, adopted and promulgated, subject to revision as changing conditions require, Pollution Control Standards 1997 Revision for the modification or treatment of all sewage from municipalities or other political subdivisions, public or private institutions, corporations or watercraft, and for the modification or treatment of all industrial wastes discharged or permitted to flow into the Ohio River from the point of confluence of the Allegheny and Monongahela Rivers at Pittsburgh, Pennsylvania, designated as Ohio River mile point 0.0, to Cairo Point, Illinois, located at the confluence of the Ohio and Mississippi Rivers, and being 981.0 miles downstream from Pittsburgh, Pennsylvania.

Under the terms and provisions of the Ohio River Valley Water Sanitation Compact, all sewage from municipalities or other political subdivisions, public or private institutions, corporations or watercraft and all industrial wastes discharged or permitted to flow into the Ohio River will be required to be modified or treated to the extent specified in the standards established as above set forth.

To the extent that Pollution Control Standards (1993 Revision), which were established by Commission action September 9, 1993, have been amended or restated by virtue of Pollution Control Standards 1997 Revision, the Pollution Control Standards 1993 Revision, including any definitions and application procedures appended to or incorporated therein, are rescinded.



Alan H. Vicory, Jr.
Executive Director and Chief Engineer

ORSANCO



TABLE OF CONTENTS

I.	AUTHORITY AND PURPOSE	1
II.	DEFINITIONS.....	2
III.	DESIGNATED USES	5
IV.	WATER QUALITY CRITERIA	5
	A. General.....	5
	B. Aquatic Life Protection.....	6
	C. Human Health Protection.....	8
	D. Site-Specific Criteria.....	9
V.	WASTE WATER DISCHARGE REQUIREMENTS.....	10
	A. General.....	10
	B. Sewage.....	10
	C. Industrial Wastes, Including Toxic Wastes.....	13
	D. Residues from Potable Water Treatment Plants	13
	F. Combined Sewer Overflows.....	14
	F. Cooling Water.....	14
	G. Other Wastes.....	15
VI.	MIXING ZONE DESIGNATION	15
VII.	LIMITATION	16
VIII.	VARIANCE.....	16
IX.	ANALYTICAL METHODS	16
X.	SEVERABILITY CLAUSE	17
APPENDIX A:	Combinations of Values for Total Ammonia N, Temperature and pH Which Yield an Un-ionized Ammonia Concentration of .05 mg/L.....	18
APPENDIX B:	Critical Flow Values	19
APPENDIX C:	Numerical Values of Cadmium, Copper, Lead and Zinc Criteria at Specified Hardness Levels.....	20

Ohio River Valley Water Sanitation Commission

POLLUTION CONTROL STANDARDS

for discharges to the Ohio River

1997 Revision

I. AUTHORITY AND PURPOSE

The Ohio River Valley Water Sanitation Compact was signed in 1948 by the Governors of the States of Illinois, Indiana, Kentucky, New York, Ohio, Pennsylvania, Virginia, and West Virginia, following the consent of the United States Congress and enactment of the Compact into law by the legislatures of the eight states. The Compact created the Ohio River Valley Water Sanitation Commission as a body corporate with powers and duties set forth in it for the purpose of abating water pollution within the Compact District. Article I of the Compact mandates that all waters in the District be placed and maintained in a satisfactory, sanitary condition, available for certain beneficial uses. It is the mission of the Commission to insure protection of these uses and to preserve the waters for other legitimate purposes.

The Compact grants the Commission authority to carry out its mission. Article VI states that "The guiding principle of this Compact shall be that pollution by sewage or industrial wastes originating within a signatory state shall not injuriously affect the various uses of the interstate waters." Minimum requirements for the treatment of sewage and industrial waste are then established in Article VI, as well as the authority of the Commission to require higher degrees of treatment where they are determined to be necessary after investigation, due notice, and hearing. Article VI concludes by authorizing the Commission to "adopt, prescribe, and promulgate rules, regulations and standards for administering and enforcing the provisions of this article."

Article X of the Compact grants the Commission authority to issue orders, after investigation and hearing, for the purpose of achieving compliance with its standards. Any court of general jurisdiction or any United States District Court in the signatory states may be used by the Commission in order to enforce such orders.

It is the policy of the Commission to rely on the member states for the primary enforcement of its standards. Each of the member states is authorized to do so under the legislation that enabled its membership in the Compact. Each of the member states is authorized to administer the federal/state National Pollutant Discharge Elimination System (NPDES) as established in Section 402 of the Federal Clean Water Act. Sections 301(b)(1)(C) and 510 of the Federal Act provide that permits issued under that system may incorporate applicable standards promulgated by an interstate agency wherever they are more stringent than comparable state or federal standards. The NPDES permits are therefore the primary means by which the Commission standards are implemented and enforced.

These Standards set forth the uses to be protected in the Ohio River (Section III), as established in the Compact; establish water quality criteria to assure that those uses will be achieved (Section IV), and set waste water discharge requirements (Section V) needed to attain the water quality criteria. The Standards also recognize the right of individual states to adopt and apply more stringent regulations.

Specific waste water discharge requirements are established in these regulations and must be incorporated into discharge permits issued under the authority of the National Pollutant Discharge Elimination System or state discharge permitting programs when they are more stringent than:

- 1) applicable U.S. EPA technology-based effluent guidelines required under Sections 301, 304, 306, and 307 of the Federal Clean Water Act, or
- 2) any state treatment requirements, effluent standards, or water quality-based effluent limits.

In the absence of promulgated Federal effluent guidelines pursuant to Sections 301, 304, 306, and 307 of the Clean Water Act, the Compact signatory states have the responsibility to establish effluent limitations to be included in any discharge permit, consistent with the standards contained herein using Best Professional Judgement on a case-by-case basis.

II. DEFINITIONS

- A. "Acute criteria" means the highest instream concentrations of toxic substances to which organisms can be exposed for a brief period of time (as measured by approved short-term exposure tests) without causing mortality or other unacceptable effects.
- B. "Biological integrity" means the ability of an aquatic ecosystem to support and maintain a balanced, integrated, adaptive community of organisms having a species composition.

diversity, and functional organization comparable to those best attainable given ecoregional attributes and the modified habitat types of the river.

- C. “Chronic Criteria” means the highest concentrations of toxic substances to which organisms can be exposed indefinitely without causing long-term harmful effects on growth and/or reproduction or other unacceptable effects (as measured by approved long-term exposure tests).
- D. “Combined Sewer Overflow” means a discharge from a sewer system designed to convey sanitary waste waters and storm water through a single-pipe system to a treatment facility, at a point in the system prior to the treatment facility.
- E. “Compact,” as used in these regulations, means the Ohio River Valley Water Sanitation Compact and is an agreement entered into by and between the states of Indiana, West Virginia, Ohio, New York, Illinois, Kentucky, Pennsylvania, and Virginia, which pledges each to the other of the signatory states faithful cooperation in the control of existing and future pollution of the waters in the Ohio River basin. This Compact created the Ohio River Valley Water Sanitation Commission (ORSANCO).
- F. “Cooling Water” means water used as a heat transfer medium for once-through cooling or cooling tower blow down to which no industrial wastes, toxic wastes, residues from potable water treatment plants, untreated sewage, or other wastes, exclusive of antifouling agents approved by the appropriate regulatory agencies, are added prior to discharge.
- G. “Contact Recreation” means recreational activities where the human body may come in direct contact with water of the Ohio River.
- H. “Industrial Wastes” means any liquid, gaseous, solid materials or waste substances or combination thereof other than cooling water as herein defined, resulting from any process or operation including storage and transportation, manufacturing, commercial, agricultural, and government operations.
- I. “Mixing Zone” means that portion of the water body receiving a discharge, where effluent and receiving waters are not totally mixed and uniform, with the result that the zone is not representative of the receiving waters and may not meet all ambient water quality standards or other requirements of any signatory state applicable to the particular receiving waters.
- J. “Net Discharge” is determined by excluding the amount of pollution in an intake water when determining the quality of a discharge if both the intake and discharge are from and to the same body of water.
- K. “96 hour LC₅₀” as used in these regulations means the concentration of a substance that kills 50 percent of the test organisms within 96 hours. The test organisms shall be representative important species indigenous to the Ohio River or standard test organisms.

- L. The "Ohio River," as used in these regulations, extends from the point of confluence of the Allegheny and Monongahela Rivers at Pittsburgh, Pennsylvania, designated as Ohio River mile point 0.0 to Cairo Point, Illinois, located at the confluence of the Ohio and Mississippi Rivers and being 981.0 miles downstream from Pittsburgh.
- M. "Ohio River Valley Water Sanitation Commission" (Commission) means a body corporate created by authority of the Compact and is the operating agency established to implement the Compact. It consists of three representatives of each signatory state and three representatives of the Federal government.
- N. "Other Wastes" means any waste other than sewage, cooling water, residues from potable water treatment plants, industrial wastes or toxic wastes, which if discharged to the Ohio River could cause or contribute to any violations of these regulations, or of any water quality standards of any signatory state or which may be deleterious to the designated uses.
- O. "Persistent Substances" means those substances which have a half-life for degradation under natural environmental conditions of more than four days. All other substances are non-persistent.
- P. "Representative Aquatic Species" means those species of aquatic life whose protection and propagation will assure the sustained presence of a balanced indigenous community. Such species are representative in the sense that maintenance of suitable water quality conditions will assure the overall protection and sustained propagation of the balances indigenous community.
- Q. "Residues from Potable Water Treatment Plants" means those wastes emanating from processes used in water purification. Such processes may include sedimentation, chemical coagulation, filtration, iron and manganese removal, softening and disinfection.
- R. "Sewage" means water-carried human or animal wastes from such sources as residences; industrial, commercial, or government establishments; public or private institutions; or other places. For the purposes of these Standards, the admixture of sewage with industrial wastes, toxic wastes, or other wastes shall be subject to treatment requirements for those types of wastes, but shall also be regarded as sewage.
- S. "Substantially Complete Removal;" means removal to the lowest practicable level attainable with current technology.
- T. "Toxic Wastes" means wastes containing substances or combinations of substances in concentrations which might reasonably be expected to cause death, disease, behavioral abnormalities, genetic mutations, physiological malfunctions including those in reproduction, or physical deformations in fish, other aquatic life, wildlife, livestock, or humans.

- U. "Waste water" means sewage and/or industrial wastes as herein defined.

III. DESIGNATED USES

The Ohio River, as hereinbefore, defined, has been designated by the Compact as available for safe and satisfactory use as public and industrial water supplies after reasonable treatment, suitable for recreational usage, capable of maintaining fish and other aquatic life and adaptable to such other uses as may be legitimate. It is the purpose of these Pollution Control Standards to safeguard the waters of the Ohio River for these designated uses. No degradation of the water quality of the Ohio River which would interfere with, or become injurious to, these uses shall be permitted.

IV. WATER QUALITY CRITERIA

A. General

The minimum conditions which the waste water discharge requirements (Section V) are intended to achieve in the receiving waters outside the mixing zone are as follows:

1. Freedom from anything that will settle to form objectionable sludge deposits which interfere with designated water uses.
2. Freedom from floating debris, scum, oil and other floating material in amounts sufficient to be unsightly or deleterious.
3. Freedom from materials producing color or odors to such a degree as to create unaesthetic conditions or a nuisance.
4. Freedom from substances in concentrations which are toxic or harmful to humans, animals, or fish and other aquatic life; which would in any manner adversely affect the flavor, color, odor, or edibility of fish and other aquatic life, wildlife, or livestock; or which are otherwise detrimental to the designated uses specified in Section III.

B. Aquatic Life Protection

To provide protection of warm water aquatic life habitats, the following criteria shall be met outside the mixing zone:

1. **BIOLOGICAL:** The biological integrity of the Ohio River shall be protected and preserved.
2. **DISSOLVED OXYGEN:** The average concentration shall be at least 5.0 mg/L for each calendar day; the minimum concentration shall not be less than 4.0 mg/L. During the April 15-June 15 spawning season, a minimum concentration of 5.0 mg/L shall be maintained at all times.
3. **TEMPERATURE:** Allowable stream temperatures are:

<u>Month/Date</u>	<u>Period Average</u>		<u>Instantaneous Maximum</u>	
January 1-31	45°F	7.2°C	50°F	10.0°C
February 1-29	45	7.2	50	10.0
March 1-15	51	10.6	56	13.3
March 16-31	54	12.2	59	15.0
April 1-15	58	14.4	64	17.8
April 16-30	64	17.8	69	20.6
May 1-15	68	20.0	73	22.8
May 16-30	75	23.9	80	26.7
June 1-15	80	26.7	85	29.4
June 16-30	83	28.3	87	30.6
July 1-31	84	28.9	89	31.7
August 1-31	84	28.9	89	31.7
September 1-15	84	28.9	87	30.6
September 16-30	82	27.8	86	30.0
October 1-15	77	25.0	82	27.8
October 16-31	72	22.2	77	25.0
November 1-30	67	19.4	72	22.2
December 1-31	52	11.1	57	13.9

4. **pH:** No value below 6.0 nor above 9.0.
5. **AMMONIA:** The concentration of un-ionized ammonia as (NH₃) shall not exceed 0.05 mg/L; un-ionized ammonia shall be determined from values for total ammonia (as nitrogen), pH and temperature, by means of the following equation:

$$Y = \frac{1.2 (\text{Total ammonia-N})}{[1 + 10^{pk_a - pH}]}$$

$$pk_a = 0.0902 + \frac{2730}{(273.2 - T_c)}$$

Where:

T_c = Temperature, degrees Celsius
 Y = Un-ionized ammonia, milligrams per liter

Combinations of values for total ammonia (as nitrogen), pH, and temperature which yield an un-ionized ammonia concentration of 0.05 mg/L are shown in Appendix A.

6. CHEMICAL CONSTITUENTS:

a. Not to exceed the following concentrations:

Constituent	Chronic Criteria Concentration	Acute Criteria Concentration
	ug/L	ug/L
Cadmium	$e^{(0.7852[\ln \text{Hard.}] - 3.490)}$	$e^{(1.128[\ln \text{Hard.}] - 3.828)}$
Chromium (hexavalent)	11	16
Copper	$e^{(0.8545[\ln \text{Hard.}] - 1.465)}$	$e^{(0.9422[\ln \text{Hard.}] - 1.464)}$
Cyanide (free)	5	22
Lead	$e^{(1.273[\ln \text{Hard.}] - 4.705)}$	$e^{(1.273[\ln \text{Hard.}] - 1.464)}$
Mercury	1.3	2.4
Selenium	5	20
Zinc	$e^{(0.8473[\ln \text{Hard.}] + 0.7614)}$	$e^{(0.8473[\ln \text{Hard.}] - 0.8604)}$

b. Concentrations for metals are total recoverable (except hexavalent chromium which is dissolved) unless it can be demonstrated to the satisfaction of the Commission and the member states, that a more appropriate analytical technique is available which provides a measurement of that portion of the metal present which causes toxicity to aquatic life.

c. Waste water discharge requirements for these constituents shall be calculated based on the chronic criteria concentrations, the in-stream concentration above the point of discharge, and the minimum 7-day, 10-year stream flow as contained in Appendix B. The acute criteria concentrations shall not be exceeded in the stream at any time. Criteria for cadmium, copper, lead, and zinc at specified hardness values are listed in Appendix C.

7. OTHER TOXIC SUBSTANCES:

Water quality criteria for substances not otherwise specified in this section shall be derived based on the following:

a. For the Protection of Aquatic Life:

i. Non-Persistent Substances - not to exceed an average of one-twentieth (0.05), nor at any time exceed one-tenth (0.1) of the 96 hour LC₅₀ of representative important species indigenous to the Ohio River or standard test organisms.

ii. Persistent Substances - not to exceed an average of one one-hundredth (0.01), nor at any time exceed one-twentieth (0.05) of the 96 hour LC₅₀ of representative important species indigenous to the Ohio River or standard test organisms.

b. Limiting concentrations other than those derived from the above may be used for the protection of aquatic life when justified on the basis of scientifically defensible evidence.

C. Human Health Protection

To provide protection to human health, the following criteria shall be met outside the mixing zone:

1. BACTERIA:

a. Maximum allowable level of fecal coliform bacteria for use as a source of public water supply -- For the months of November through April, content shall not exceed 2,000/100 mL as a monthly geometric mean based on not less than five samples per month.

b. Maximum allowable level of fecal coliform bacteria for contact recreation -- For the months of May through October, content shall not exceed 200/100 mL as a monthly geometric mean based on not less than five samples per month; nor exceed 400/100 mL in more than 10 percent of all samples taken during the month.

c. Maximum allowable level of *Escherichia coli* bacteria for contact recreation -- For the months of May through October, measurements of *Escherichia coli* bacteria may be substituted for fecal coliform. Content shall not exceed 130/100 mL as a monthly geometric mean, based on not less than five samples per month, nor exceed 240/100 mL in any sample.

2. CHEMICAL CONSTITUENTS:

Not to exceed the following concentrations:

<u>Constituents</u>	<u>Concentration (mg/L)</u>
Arsenic	0.05
Barium	1.0
Chloride	250
Fluoride	1.0
Mercury	0.000012
Nitrite + Nitrate Nitrogen	10.0

<u>Constituents</u>	<u>Concentration (mg/L)</u>
Nitrite Nitrogen	1.0
Phenolics	0.005
Silver	0.05
Sulfate	250

3. RADIONUCLIDES: Gross total alpha activity (including radium-226 but excluding radon and uranium) shall not exceed 15 picocuries per liter (pCi/L) and combined radium-226 and radium-228 shall not exceed 4 pCi/L. Concentration of total gross beta particle activity shall not exceed 50 pCi/L; the concentration of total Strontium-90 shall not exceed 8 pCi/L.
4. OTHER TOXIC SUBSTANCES: Water quality criteria for substances not otherwise specified in this section shall be derived based on the following:
 - a. For the protection of human health, criteria published by the United States Environmental Protection Agency pursuant to Section 304(a) of the Federal Clean Water Act shall be used.
 - i. For substances identified as human carcinogens, waste water discharge requirements shall be developed based on the in-stream concentration above the point of discharge, and calculated so as to prevent one additional cancer per one million population at the harmonic mean stream flow (see Appendix B).
 - ii. For substances not identified as human carcinogens, waste water discharge requirements shall be developed based on the in-stream concentration above the point of discharge and calculated to meet the water quality criteria at the minimum 7-day, 10-year flow (see Appendix B).
 - b. Limiting concentrations other than those derived from the above may be used for the protection of human health when justified on the basis of scientifically defensible evidence.

D. Site-Specific Criteria

Alternative site-specific criteria for the constituents listed herein may be approved if they are demonstrated to be appropriate to the satisfaction of the Commission. Such demonstrations shall utilize methods contained in the Water Quality Standards Handbook (US EPA publication EPA823-B94005A, August 1994).

V. WASTE WATER DISCHARGE REQUIREMENTS

A. General

1. No discharge of sewage, industrial wastes, toxic wastes, other wastes, cooling water or residues from potable water treatment plants shall cause or contribute to a violation of these waste water discharge requirements, shall preclude the attainment of any designated use of the main stem waters of the Ohio River or shall interfere with the attainment of the water quality criteria set forth in Section IV.
2. All discharges of sewage, industrial wastes, toxic wastes, other wastes, cooling water or residues from potable water treatment plants shall be treated or otherwise modified so as to provide:
 - a. Substantially complete removal of settleable solids, which may form sludge deposits;
 - b. Substantially complete removal of oil, debris, scum and other floating material;
 - c. Reduction of total suspended solids and other materials to such a degree that the discharge will not produce a substantial negative visible contrast to natural conditions in turbidity, color or odor of the river, or impart taste to potable water supplies or cause tainting of fish flesh;
 - d. Reduction of all substances in amounts which, when concentrated or combined in the receiving stream, would result in conditions toxic or harmful to humans, animals, or fish and other aquatic life; which would in any manner adversely affect the flavor, color, odor, or edibility of fish and other aquatic life, wildlife, or livestock; or which are otherwise detrimental to the designated water uses specified in Section III.

B. Sewage

1. MINIMUM LEVEL OF TREATMENT:

Sewage shall be treated, prior to discharge, to meet the following effluent limitations in addition to the requirements of Section V.A.

a. Biochemical Oxygen Demand

i. Five-day biochemical oxygen demand (BOD₅) - the arithmetic mean of the values for effluent samples collected in a month shall not exceed 30 mg/L, and the arithmetic mean of the values for effluent samples collected in a week shall not exceed 45 mg/L.

ii. Five-day carbonaceous biochemical oxygen demand (CBOD₅) may be substituted for BOD₅ provided that the arithmetic mean of the values for effluent samples collected in a month shall not exceed 25 mg/L, and the arithmetic mean of the values of effluent samples collected in a week shall not exceed 40 mg/L.

b. Suspended Solids

The arithmetic mean of the values for effluent samples collected in a month shall not exceed 30 mg/L, and the arithmetic mean of the values for effluent samples collected in a week shall not exceed 45 mg/L.

c. pH

The effluent values for pH shall be maintained within the limits of 6.0 to 9.0.

d. Bacteria

i. During the months of November through April, the geometric mean of the fecal coliform bacteria content of effluent samples collected in a month shall not exceed 2000/100 mL.

ii. During the months of May through October, the geometric mean of the fecal coliform bacteria content of effluent samples collected in a month shall not exceed 200/100 mL, and no more than 10 percent of the values shall exceed 400/100 mL.

iii. During the months of May through October, *Escherichia coli* may be substituted for fecal coliform provided that the geometric mean of the values for effluent samples collected in a month shall not exceed 130/100 mL, and no more than 10 percent of the values shall exceed 240/100 mL.

2. ALTERNATIVE TREATMENT:

Such facilities as waste stabilization ponds and trickling filters shall be deemed to provide effective treatment of sewage provided that the requirements of Sections V.A, V.B1 (c) and (d) are met, that the effluent does not cause any violations of applicable states' water quality standards or Sections III and IV of these regulations, and that the following requirements are met.

a. Biochemical Oxygen Demand

i. Five-day biochemical oxygen demand (BOD₅) -- the arithmetic mean of the values for effluent samples collected in a month shall not exceed 45 mg/L; and the arithmetic mean of the values for effluent samples collected in a week shall not exceed 65 mg/L.

ii. Five-day carbonaceous biochemical oxygen demand (CBOD₅) may be substituted for BOD₅, provided that the levels are not less stringent than the following: the arithmetic mean of the values for effluent samples collected in a month shall not exceed 40 mg/L and; the arithmetic mean of the values for effluent samples collected in a week shall not exceed 60 mg/L.

b. Suspended Solids

The arithmetic mean of the values for effluent samples collected in a month shall not exceed 45 mg/L; and the arithmetic mean of the values for effluent samples collected in a week shall not exceed 65 mg/L.

3. TREATMENT OF FLOWS FROM COMBINED SEWER SYSTEMS DURING WET WEATHER CONDITIONS

In cases where municipal wastewater treatment plants serving combined sewer areas have primary treatment capacity in excess of secondary treatment capacity, opportunities may exist for partial treatment of combined flows which would otherwise be discharged as untreated combined sewer overflows. In such cases, in order to maximize the treatment of wet weather flows from combined sewer systems and reduce the frequency and duration of combined sewer overflow (CSO) events, bypass of the secondary treatment during wet weather conditions may be allowed on an interim basis, provided the following conditions are met:

1. the facilities are properly operated and maintained,
2. the maximum possible quantity of waste water (determined through an approved engineering study) receives secondary treatment in accordance with discharge requirements, and
3. the discharge does not cause exceedances of water quality criteria in the Ohio River outside the mixing zone.

Bypasses of secondary treatment which are necessary in order to implement a CSO long-term control plan which includes primary treatment options at the municipal wastewater treatment plant may be allowed, provided it is not technically or financially feasible to provided secondary treatment of greater amounts of wet weather flow. The consideration of feasible alternatives should be documented in the development of the long-term control plan.

C. Industrial Wastes, Including Toxic Wastes

1. The minimum level of treatment for industrial wastes including toxic wastes, prior to discharge shall be in accordance with national effluent limitations and guidelines adopted by the Administrator of the United States Environmental Protection Agency pursuant to Sections 301 and 302 of the Federal Clean Water Act, national standards of performance for new sources adopted pursuant to Section 306 of the Federal Clean Water Act, and national toxic and pretreatment effluent limitations, adopted pursuant to Section 307 of the Federal Clean Water Act or in accordance with the standards of the state in which the discharge occurs.
2. In addition, the net discharge of the following toxic pollutants is prohibited:
 - a. Aldrin (a,s,3,4,10,10-hexachloro-1,4,4a,5,8,8a-hexahydro-1, 4-endo-5, 8-exo-dimethanonaphthalene)
 - b. Dieldrin (a,2,3,4,10,10-hexachloro-6, 7-epoxy-1,4,4a,5,6,7,8,8a-octahydro-1, 4-endo-5, 8-exo-dimethanonaphthalene)
 - c. DDT, including DDD and DDE
 - i. DDT means 1,1,1-trichloro-2,2-bis(p-chlorophenyl) ethane and some o,p'-isomers
 - ii. DDD (TDE) means 1,1-dichloro-2, 2-bis(p-chlorophenyl) ethane and some o,p'-isomers
 - iii. DDE means 1,1-dichloro-2, 2-bis(p-chlorophenyl) ethylene
 - d. Endrin (1,2,3,4,10,10-hexachloro-6, 7-epoxy-1, 4,4a,5,6,7,8,8a-octahydro-1, 4-endo-5, 8-endo-dimethanonaphthalene)
 - e. Toxaphene - a material consisting of technical grade chlorinated camphene having the approximate formula of $C_{10}H_{10}Cl_8$ and normally containing 67-69 percent chlorine by weight.
 - f. Benzidine - the compound benzidine and its salts as identified by the chemical name 4,4-diaminobiphenyl
 - g. Polychlorinated Biphenyls (PCB) - a mixture of compounds composed of the biphenyl molecule which has been chlorinated to varying degrees.

D. Residues from Potable Water Treatment Plants

The use of controlled discharge for residues from potable water treatment plant processes of sedimentation, coagulation and filtration may be authorized provided that, as a minimum, the discharge meets all the requirements of Section IV.A and V.A.

E. Combined Sewer Overflows

1. A direct discharge, if caused by temporary excess flows due to storm water collected and conveyed through combined sewer systems, shall not be considered to be in violation of these waste water discharge requirements, providing that the discharger is demonstrating compliance with the nine minimum controls as specified in the U.S.EPA's national Combined Sewer Overflow Control Policy (EPA 830-B-94-001, April 1994). The nine minimum controls are as follows:
 1. proper operation and regular maintenance programs for the sewer system and the CSOs;
 2. maximum use of the collection system for storage;
 3. review and modification of pretreatment requirements to assure CSO impacts are minimized;
 4. maximization of flow to the POTW for treatment;
 5. prohibition of CSOs during dry weather;
 6. control of solid and floatable materials in CSOs;
 7. pollution prevention;
 8. public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts;
 9. monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.

In addition, the discharge must not interfere with the attainment of the water quality criteria set forth in Section IV.

2. No discharges to the Ohio River shall occur from combined sewer regulating devices unless there has been rainfall in greater than trace amounts or significant melting of frozen precipitation during the immediately preceding 24-hours, or unless the discharge is caused by river elevation at or above the established flood stage.

F. Cooling Water

1. A discharge of cooling water shall meet the requirements of Section V.A and shall not cause violations of the temperature criteria set forth in Section IV.B.3, except as authorized by a variance issued pursuant to Section 316(a) of the Federal Clean Water Act.
2. Any anti-fouling agent added to a cooling water which will ultimately be discharged to the environment must be approved by the appropriate state agency.

G. Other Wastes

The discharge of Other Wastes (other than those specified above) shall meet the requirements of Section V.A and shall not cause or contribute to a violation of the water quality criteria set forth in Section IV.

VI. MIXING ZONE DESIGNATION

- A. Where mixing zones are allowed by the permitting authority, the specific numerical limits for any mixing zone shall be determined on a case-by-case basis, and shall include considerations for existing uses, linear distance (i.e., length and width) from the point of discharge, surface area involved, and volume of receiving water within the defined zone.
- B. Conditions within the mixing zone shall not be injurious to human health, in the event of a temporary exposure.
- C. Acute water quality criteria, as specified in Section IV.B.6, will apply at all points within the mixing zone; however, states may at their discretion allow a smaller zone in the immediate vicinity of the point of discharge, in which acute criteria are exceeded provided the zone does not impact the water of another state.
- D. The mixing zone shall be free from substances attributable to sewage, industrial wastes, toxic wastes, other wastes, cooling water, or residues from potable water treatment plants in quantities which:
1. Settle to form sludge deposits;
 2. Float as debris, scum, or oil;
 3. Contaminate natural sediments so as to cause or contribute to a violation of:
 - a. appropriate stream criteria outside the mixing zone, or
 - b. any condition of the designated uses of the water.
 4. Impart a disagreeable flavor or odor to flesh of fish or other aquatic life, wildlife or livestock which are consumed by man and which acquire such a flavor because of passage through or ingestion of the waters from the mixing zone.
- E. The mixing zone shall be located so as not to interfere significantly with migratory movements and passage of fish, other aquatic life, and wildlife. No mixing zone shall adversely impact water quality so as to interfere with potable or industrial water supplies, bathing areas, reproduction of fish, other aquatic life and wildlife.

VII. LIMITATION

Nothing contained in these regulations shall be construed to limit the powers of any state signatory to the Compact to promulgate more stringent criteria, conditions and restrictions to further lessen or prevent the pollution of waters within its jurisdiction.

VIII. VARIANCE

- A. The Commission may grant a variance from the provisions of Section V of these Standards, provided that the uses set forth in Section III are maintained and that the water quality criteria set forth in Section IV are met. The applicant for a variance shall adhere to the following:
1. The specific reasons for the variance shall be clearly stated in writing;
 2. The burden of proof is upon the applicant to assure that the uses set forth in Section III are maintained;
 3. Prior concurrence of the state where the applicant's discharge is located and those state(s) which may be affected must be obtained;
 4. Such additional information shall be provided to the Commission as it may request.
- B. A variance may be granted for a period not to exceed the life of the applicable discharge permit; the applicant may apply for a variance renewal prior to the expiration of the permit.

IX. ANALYTICAL METHODS

Tests or analytical determinations to determine compliance or non-compliance with the Waste Water Discharge Requirements and stream criteria established herein shall be made in accordance with accepted procedures such as those contained in the: (a) latest edition of Standard Methods for the Examination of Water and Waste Water prepared and published jointly by the American Public Health Association (APHA), American

Water Works Association (AWWA), and Water Environment Federation (WEF); (b) Annual Book of ASTM Standards, Part 31 - Water published by the American Society for Testing and Materials; (c.) Guidelines Establishing Test Procedures for the Analysis of Pollutants (40 CFR 136) by the U.S. Environmental Protection Agency; or (d) by such other methods as are approved by the Commission as equal or superior to or not available within methods in documents listed above, provided such other test methods are available to the public.

X. SEVERABILITY CLAUSE

Should any one or more of the Pollution Control Standards hereby established or should any one or more provisions of the regulations herein contained be held or determined to be invalid, illegal or unenforceable, for any reason whatsoever, all other Standards and other provisions shall remain effective.

APPENDIX A

COMBINATIONS OF VALUES FOR TOTAL AMMONIA (AS NITROGEN), TEMPERATURE AND pH WHICH YIELD AN UN-IONIZED AMMONIA CONCENTRATION OF .05 MG/L

pH	T _r		50		55		59		64		68		70		72		75		77		80		84		86		89	
	T _c	5	7.2	10	10	12.8	15	15	17.8	20	20	21.1	21.1	21.1	22.2	23.9	23.9	25	25	24	25	26.7	28.9	30	30	31.7	31.7	
6.5	106	89	71	58	48	39	33	31	28	25	24	20	18	16	14	13	10	9.4	8.2	7.2	6.5	5.7	5.2	4.6	4.1	3.7		
6.6	84	71	56	46	38	31	27	25	23	20	19	16	14	13	11	10	8.2	7.5	6.5	5.7	5.3	4.5	4.1	3.6	3.3	2.9		
6.7	67	56	46	36	30	25	21	20	18	16	15	13	11	10	9.0	8.2	7.2	6.5	5.7	5.3	4.5	4.1	3.6	3.3	2.9	2.3		
6.8	53	45	36	29	24	20	17	16	14	13	12	10	9.8	9.0	8.2	7.2	6.5	5.7	5.3	4.5	4.1	3.6	3.3	2.9	2.3	1.9		
6.9	42	36	28	23	19	16	13	12	11	10	9.4	8.0	7.8	7.2	6.5	5.7	5.3	4.5	4.1	3.6	3.3	2.9	2.6	2.3	1.9	1.5		
7.0	33	28	22	18	15	12	11	11	9.8	9.0	8.0	7.2	6.2	5.7	5.3	4.5	4.1	3.6	3.3	2.9	2.6	2.3	2.1	1.9	1.5	1.2		
7.1	27	22	18	14	12	9.8	8.4	7.8	7.2	6.5	5.9	5.1	4.7	4.1	3.6	3.3	2.9	2.6	2.3	2.1	1.9	1.7	1.5	1.3	1.2	1.1		
7.2	21	18	14	12	9.7	7.8	6.7	6.2	5.7	5.1	4.7	4.0	3.8	3.3	2.9	2.6	2.3	2.1	1.9	1.8	1.7	1.5	1.3	1.2	1.1	.95		
7.3	17	14	11	9.2	7.7	6.2	5.3	4.9	4.5	4.0	3.8	3.2	3.0	2.6	2.3	2.1	1.9	1.8	1.7	1.5	1.3	1.2	1.1	.94	.85	.777		
7.4	13	11	8.9	7.3	6.1	4.9	4.2	3.9	3.6	3.2	3.0	2.6	2.4	2.1	1.9	1.8	1.7	1.5	1.3	1.2	1.1	.94	.85	.76	.69	.62		
7.5	11	8.9	7.1	5.8	4.9	3.9	3.4	3.1	2.9	2.6	2.4	2.1	1.9	1.8	1.7	1.5	1.3	1.2	1.1	.94	.85	.76	.69	.62	.55	.50		
7.6	8.4	7.1	5.7	4.6	3.9	3.1	2.7	2.5	2.3	2.0	1.9	1.6	1.5	1.3	1.2	1.1	.94	.85	.76	.69	.62	.55	.50	.45	.40	.33		
7.7	6.7	5.7	4.6	3.7	3.1	2.5	2.1	2.0	1.8	1.6	1.5	1.3	1.2	1.1	.94	.85	.76	.69	.62	.55	.50	.45	.40	.37	.33	.27		
7.8	5.3	4.5	3.6	2.9	2.5	2.0	1.7	1.7	1.5	1.3	1.2	1.0	.94	.85	.76	.69	.62	.55	.50	.45	.40	.37	.33	.30	.27	.22		
7.9	4.2	3.6	2.9	2.3	2.0	1.6	1.4	1.4	1.3	1.2	1.0	.84	.76	.69	.62	.55	.50	.45	.40	.37	.33	.30	.27	.25	.22	.19		
8.0	3.4	2.9	2.3	1.9	1.6	1.3	1.1	1.1	1.0	.94	.84	.76	.69	.62	.55	.50	.45	.40	.37	.33	.30	.27	.25	.22	.20	.19		
8.1	2.7	2.3	1.8	1.5	1.3	1.0	.88	.82	.76	.69	.63	.57	.54	.49	.45	.40	.37	.33	.30	.27	.25	.22	.20	.19	.16	.13		
8.2	2.1	1.8	1.5	1.2	1.0	.81	.71	.66	.61	.54	.49	.44	.41	.37	.33	.30	.27	.25	.22	.20	.19	.16	.13	.12	.11	.10		
8.3	1.7	1.5	1.2	.94	.81	.65	.57	.53	.49	.44	.41	.36	.34	.30	.27	.25	.22	.20	.19	.16	.13	.12	.11	.10	.09	.09		
8.4	1.4	1.2	.93	.76	.65	.53	.46	.43	.40	.36	.34	.30	.27	.25	.22	.20	.19	.16	.13	.12	.11	.10	.09	.09	.09	.09		
8.5	1.1	.93	.75	.62	.52	.43	.38	.35	.33	.29	.28	.24	.23	.20	.19	.16	.13	.12	.11	.10	.09	.09	.09	.09	.09	.09		
8.6	.88	.75	.60	.50	.43	.35	.31	.29	.27	.24	.23	.20	.19	.16	.13	.12	.11	.10	.09	.09	.09	.09	.09	.09	.09	.09		
8.7	.71	.60	.49	.40	.35	.29	.25	.24	.22	.20	.19	.17	.16	.13	.12	.11	.10	.09	.09	.09	.09	.09	.09	.09	.09	.09		
8.8	.57	.49	.40	.33	.28	.24	.21	.20	.18	.17	.16	.14	.13	.11	.10	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09		
8.9	.46	.40	.32	.27	.23	.20	.17	.16	.16	.14	.14	.12	.11	.10	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09		
9.0	.38	.32	.27	.22	.19	.17	.15	.14	.13	.12	.12	.11	.10	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09	.09		

T_r - Temperature in degrees Fahrenheit

T_c - Temperature in degrees Centigrade

APPENDIX B

CRITICAL FLOW VALUES

FROM	TO	Minimum 7-day 10-year Low-Flow in cfs ⁽¹⁾	Harmonic Mean Flow in cfs ⁽²⁾
Pittsburgh (MP 0.0)	Montgomery Dam (MP 31.7)	4,730	16,200
Montgomery Dam (MP 31.7)	Willow Island Dam (MP 161.7)	5,880	20,500
Willow Island Dam (MP 161.7)	Racine Dam (MP 237.5)	6,560	24,500
Racine Dam (MP 237.5)	R.C. Byrd Dam (MP 279.2)	6,700	26,000
R.C. Byrd Dam (MP 279.2)	Guyandotte River (MP 305.2)	9,120	34,500
Guyandotte River (MP 305.2)	Big Sandy River (MP 317.1)	9,300	35,900
Big Sandy River (MP 317.1)	Greenup Dam (MP 341.0)	10,000	38,400
Greenup Dam (MP 341.0)	Meldahl Dam (MP 436.2)	10,600	42,100
Meldahl Dam (MP 436.2)	McAlpine Dam (MP 606.8)	10,600	45,300
McAlpine Dam (MP 606.8)	Newburgh Dam (MP 776.1)	11,000	49,000
Newburgh Dam (MP 776.1)	Uniontown Dam (MP 846.0)	12,900	60,900
Uniontown Dam (MP 846.0)	Smithland Dam (MP 918.5)	16,900	78,600
Smithland Dam (MP 918.5)	Cairo Point (MP 981.0)	51,000	175,000

⁽¹⁾Minimum 7-day, 10-year low flow (in cubic feet per second) provided by the U.S. Corps of Engineers

⁽²⁾Based on ORSANCO analysis of stream flow data provided by the U.S. Corps of Engineers

APPENDIX C

**NUMERICAL VALUES OF CADMIUM, COPPER, LEAD, AND ZINC CRITERIA
AT SPECIFIED HARDNESS LEVELS**

Hardness	Cadmium		Copper		Lead		Zinc	
	Chronic Criterion (µg/L)	Acute Criterion (µg/L)						
50	0.7	1.8	7	9	1.3	34	59	65
100	1.1	3.9	12	18	3.2	82	106	117
150	1.6	6.2	17	26	5.3	137	149	165
200	2.0	8.6	21	34	7.7	197	191	211
250	2.3	11.0	26	42	10	262	230	254
300	2.7	13.5	30	50	13	331	269	297